PORTABLE APPLIANCE INSPECTION AND TEST RECORD

Page 1 of 1 RECORD Nº 001

CONTACT NAME & SITE ADDRESS:	Mr A Davidson, 8 Edward Road, Coulsdon, Surrey CR5 2NP
CONTRACTOR'S TRADING TITLE & ADDRESS:	Pose then Pout / Mirror Image Photobooths
TEST EQUIPMENT - Make, Model and Ser. Nº:	Kewtech PAT Tester KT72 7015064

EMPLOYEE UNDERTAKING WORK: NAME (BLOCK CAPITALS): C Payne (SIGNATURE):

Room Number (location)	Appliance Description & Make, etc	Identity Nº	VISUAL CHECKS					ELECTRICAL TESTS				Comments	Date of Check	Pass (P) or Fail (F)
			Class (I, II, etc)	Fuse Rating (A)	Suitability (✓) (✗) Plug	Lead	App. casing	Earth Bond Test current (A)	Earth Bond Resistance (Ω)	Insulation Resistance MΩ	Insulation Resistance mA			
N/A	Photobooth	001	II	13A	✓	✓	✓	0·03	0·01	>20	N/A	NONE	17/7/17	P
N/A	Photomaster Mirror booth	002	II	13A	✓	✓	✓	0·03	0·01	>20	N/A	NONE	17/7/17	P
N/A	Mitsubishi Printer CPD70DW	003	II	5A	✓	✓	✓	0·04	0·01	>20	N/A	NONE	17/7/17	P
N/A	Mitsubishi Printer CPD70DW	004	II	5A	✓	✓	✓	0·03	0·01	>20	N/A	NONE	17/7/17	P
N/A	Extension Lead	005	II	13A	✓	✓	✓	N/A	0·01	>20	N/A	NONE	17/7/17	P
N/A	Extension Lead	006	II	13A	✓	✓	✓	N/A	0·01	>20	N/A	NONE	17/7/17	P

© Signal International Ltd